
Operation

- Liquids with solid particles and/or fouling require prior testing. Use filter before the Sensor to prevent the internal piston from locking. Not recommended for industrial water waste.
- Liquids with ferrous and/or magnetic particles require technical analysis: the Sensor contains magnetic components inside. Use a magnetic filter before the Sensor to avoid deposition/settling that will prejudice its operation.

Typical Connection to Contactor



! Never connect the sensor directly to a motor, pump, lamp or any other load over 20W. Always use a contactor or relay.



Installing the snubber filter extends the lifespan of the sensor's electrical contact.

K8 Snubber Filter for electrical installation (AC) (included)

1A @20ms

The sensors work in all voltage and current ranges displayed in the table bellow:						
	Operating Voltage	Max. Switching Power	Max. Switching Current	Peak Current		
	110Vac	20VA	0,2A	0,5A @20ms		
	220Vac	20VA	0,1A	0,5A @20ms		
	5Vdc	2,5W	0,5A	1A @20ms		
	12Vdc	5W	0,5A	1A @20ms		

24Vdc 10W 24Vac: NOT recommended

Term of Warranty

For installations according to this guide: 02 (two) years warranty. **INCORRECT INSTALLATION CANCELS THE WARRANTY.** All Sensors have been tested and approved during the manufacture process.

🖑 On **datasheets.eicos.us** available technical specifications

+55 (15) 3032.9190

Electrical Contact of Sensors - Attention to Install

Reed Switch 20W/VA: Protect the Electrical Contact of your Sensor



Reed Switches are hermetically sealed contacts actuated by a magnetic field.

0.5A

The life expectancy of a reed switch refers to a kind of load to be used. Reed Switches of the highest reliability are applied in our sensors, and their life expectancy can reach above two million operations. However, when they are switching lamps, inductive or capacitive loads, this number may decrease.

Switching Power

It is important to consider that the power specified by an electrical load is often referred to the permanent working state.

For higher power, use an auxiliary relay or contactor as recommended below, or similar.


Siemens 3RT1015 Contactor Initial: 31.7VA Rated: 5.1VA



*For sale on accessories.eicos.us


PROTECTION PROCEDURES BELOW DESCRIBED CAN IMPROVE THE REED SWITCH PERFORMANCE

• Switching inductive loads



? Risk of failure (welding of the Reed Switch Contact) due to CAPACITANCE, which can occur depending on the distance and cable used in the connection to the contactor.

· Connecting the sensor to a contactor in long distances, use resistor:



Important: For distances greater than 40m, use 24Vdc voltage.

• Connecting the sensor to an electronic equipment:

220R 5W	
P_	e 🔄 •Timing relay
K	•Frequency inverter
	•
	4

Mimportant: For installation with **relay coupler**, use 4K7 10W resistor.

contactor and K8* snubber filter.

Note: Reed Switches have reached over one million operations in tests with

Suitable for Detection of High Flows

Fluid flow through the sensor triggers precise displacement of a magnetic piston acting on an electrical contact (Reed Switch).

Technical Specifications



(in LPM)

From ~2.5 to ~112

From ~3.3 to ~140

	PPA (Polyphthalamide)
Spring	AISI 302 stainless steel
Internal clearance	680mm ²
Maximum operating pressure	25bar
Operating temperature range	0°C to 100°C 140°C @1h
	G 1 1/2" female (BSP - Parallel)
	NBR (nitrilic rubber) O'Ring
	DIN 43650 - B Connector
Enclosure rating	
Electrical contact	Reed Switch 20W/VA (NA SPST)
Weight	

Installation


• In applications without excessive vibration;

FJ112B02


FJ112B04

- Minimum distance of 20mm from any ferrous surface;
- Mounting with parallel port connection and O'Ring.

Sealing



Flow Rate Sensitivity Adjustment



Maintenance

- Open the plug, remove the spring and clean using a brush if there is encrustation;
- 2. Mount the sensor again as illustrated beside;
- **3.** Test the electrical contact using an ohmmeter, moving the magnetic piston.

Mounting

Dimensions in millimeters.

